

**ORDER: APPROVE VARIANCE REQUEST TO USE ALTERNATIVE FIRE
PROTECTION OF DRY WELL AND POND FOR NORTH GROVE
EQUESTRIAN PARK.**

Motion was made by Kevin Frye, duly seconded by David Rikard, to approve variance request to use alternative fire protection of dry well and pond for North Grove Equestrian Park.


The vote on the motion was as follows:

Supervisor Kevin Frye, voted yes
Supervisor Jeff Busby, voted yes
Supervisor David Rikard, voted yes
Supervisor Chad McLarty, voted yes
Supervisor Mike Roberts, voted yes

After the vote, President Busby, declared the motion carried, this the 4th day of December, 2017.



Jeff Busby, President
Board of Supervisors



Sherry Wane, Chancery Clerk



WILLIAMS ENGINEERING CONSULTANTS, INC.
Professional Engineers | Professional Land Surveyors

November 6, 2017

Lafayette County Planning Commission
c/o Larry Britt
PO Box 308
Oxford, MS 38655

RE: North Grove Equestrian Park
1357 Hwy 6 East
Wes Misenheimer
Lafayette County, MS

Dear Mr. Britt,

Williams Engineering Consultants, Inc. is submitting this letter in to request a variance from the requirement for Fire Protection Water Supplies in the 2012 International Fire Code. Specifically Section 507.5 Fire Hydrant Systems.

We are requesting this variance for multiple reasons including:

- 1) The primary use of the facility is to serve as a horse stable.
- 2) The facility will be primarily made up of metal construction.
- 3) The proposed facility will be constructed more than 1,500 feet from Highway 6.
- 4) The Lafayette Springs Water Association supply line is an existing 6" PVC line located on the south side of Highway 6 to connect to the line would require the boring of Highway 6.
- 5) The proposed facility's driveway is located +/- 4000' from Lafayette County Fire Station #11.
- 6) There are multiple ponds on the property that would be suitable for the installation of Dry Hydrants. (See attached detail)

We appreciate your consideration.
If you have any questions, do not hesitate to call.

Sincerely,

Erik Jones, EI
Staff Engineer