


**ORDER: REJECT BID FOR ARENA SPRINKLER SYSTEM  
DUE TO BID BEING OVER BUDGET**

Motion was made by David Rikard, duly seconded by Cad McLarty, to reject bid for Arena sprinkler system due to bid being over budget.

The vote on the motion was as follows:

Supervisor Brent Larson, voted yes  
Supervisor Larry Gillespie, voted yes  
Supervisor David Rikard, voted yes  
Supervisor Chad McLarty, voted yes  
Supervisor Mike Roberts, voted yes

After the vote, President Roberts, declared the motion carried, this the 7<sup>th</sup> day of December, 2020.

  
\_\_\_\_\_  
Mike Roberts, President  
Board of Supervisors

  
\_\_\_\_\_  
Sherry Wall, Chancery Clerk

4 December 2020

Mr. Mike Roberts, President  
Lafayette County Board of Supervisors  
300 North Lamar Blvd.  
Oxford, MS 38655

re: Arena Sprinkler Bid Recommendation

Mr. Roberts and Supervisors,

The only bid received for the Arena Sprinkler Addition was \$257,200.00 significantly higher than our budget.

In reviewing the costs, it was recommended by the Contractor to remove the required insulation and heat trace lines from the 'wet pipe' portions of the sprinkler main piping. This would change the two types of sprinklers (wet pipe and dry pipe) to a singular dry pipe system for the entire building. The cost reduction is estimated at \$ 95,800.00.

This suggestion of a single dry pipe system throughout the Arena was reviewed and accepted by Wes Anderson.

Our recommendation is to revise the design and re-issue for bid.

Best regards,



Corey Almo Alger, Architect, AIA